

**Official Publication No. 8548**

Procurement Division  
330 2<sup>nd</sup> Ave South, Room 552  
Minneapolis, MN 55401

AN AFFIRMATIVE ACTION EMPLOYER

April 16<sup>th</sup>, 2018

Buyer Information:  
Magan Ngoto, (612) 673-3371  
[Magan.Ngoto@minneapolismn.gov](mailto:Magan.Ngoto@minneapolismn.gov)

---

**ADDENDUM NO. 4**  
**“Bid for MCC Kitchen Ductwork Replacement Project”**

**Addendum No. 4 for this project has been posted to Questcdn.com under e-bid document # 5619250.**

**Addendum No. 4 contains additional specification changes in reference to Official Publication No. 8548.**

Please consider any changes and/or corrections as part of the original bid specifications and submit your bid accordingly.

**Receipt of this addendum should be acknowledged on your bid form.**

**Bids opened 10:00 AM, Local Time, April 18<sup>th</sup>, 2018**

Finance and Property Services – Procurement Division  
City of Minneapolis

# ADDENDUM

**Date:** 4/16/18  
**Project:** MCC Kitchen Duct Work Replacement Project

**KFI Project Number:** 17-239

**Addendum Number:** 4

---

THIS ADDENDUM IS A CONTRACT DOCUMENT AND MAY APPLY TO ANY OR ALL CONTRACTS AND SUBCONTRACTS UNLESS OTHERWISE SPECIFIED HEREIN OR SHOWN ON THE ATTACHED DRAWINGS (IF ANY). ALL WORK REQUIRED BY THIS ADDENDUM SHALL BE IN COMPLETE ACCORD WITH THE CONTRACT DOCUMENTS AND SUBSEQUENT ADDENDA THERETO. THE ITEMS LISTED IN THIS ADDENDUM ARE NOT IN ANY ORDER IN REGARD TO THE DRAWINGS OR THE SPECIFICATIONS. ALL CONTRACTORS ARE CAUTIONED TO EXAMINE EACH AND EVERY ITEM OF THIS ADDENDUM.

THE FOLLOWING CHANGES OR CLARIFICATIONS TO THE PLANS & SPECIFICATIONS SHALL BE INCLUDED AS PART OF THE CONTRACT DOCUMENTS.

---

## **SPECIFICATION CHANGES:**

1. Section 23 38 13-2. Refer to Paragraph 2.02C: Hood material shall be **430 stainless steel**.
2. Section 23 38 13-2. Refer to Paragraph 2.02C8: Omit "~~Where total hood length in one run is over 12 feet,~~" and in its place add "Refer to drawings for hood section sizes,"

*END OF ADDENDUM*